


GELUIDSMETING AKOESTISCHE PANELEN

Opdrachtgever Testcentrum Meetdatum	&CO B.V. merford noise control woensdag 27 november 2013	
Productomschrijving Aantal Afmetingen Signaal Volume ontvangruimte	akoestische wand, bureau- en scheidingspanelen 6 st. 6 m ² roze ruis (pink noise) 220,8 m ³	

Frequentie [Hz]	Eq. Ab. TER [m ²]	Eq. Ab. OCT [m ²]
50	0,11	
63	0,19	0,19
80	0,26	
100	0,29	
125	0,40	0,38
160	0,47	
200	0,57	
250	0,78	0,7
315	0,74	
400	0,85	
500	0,96	0,95
630	1,03	
800	1,09	
1000	1,11	1,14
1250	1,20	
1600	1,24	
2000	1,32	1,28
2500	1,28	
3150	1,38	
4000	1,44	1,41
5000	1,41	
6300	1,43	
8000	1,30	1,33
10000	1,24	

